



In wet areas of the compressed air main all connections have to be built as swan neck from above. Exception: a sidelong connection is possible, if the collective line is at least two pipe sizes larger than the connection. The main has to be installed with a descending gradient and a condensate drain has to be provided at the lowest point.

This work may be provided with product information to initiate these tasks, however this is not a substitution for reading and understanding the appropriate Product Manuals prior to installation of the equipment.

project number status	00145180 PROPOSAL	Station setup ID 243263 Proposal 1	Station ID 39224	
			Date	Name
			Drawing	11.10.2023 Zimmer
			Check	11.10.2023 Hahnlein
			Approval	11.10.2023 Hahnlein
			Rhenus Port Logistics Regensburg / DE	
			Rhenus Port Logistics Regensburg / DE	

					P&I diagram	Sh.	Sheet size	DIN A2
					P&I diagram		1	
0		31.05.2016					297 x 420 mm	
ev.	Change	Date	Name	Orig.		Replaces	Replaced by	