

# 3512B CAT Rebuild Open – S/N Prefix LY8....

| Item                 | Description   |
|----------------------|---|
| Build Year & SMU     | 2023 - 0 Hour   |
| Rating & Application | 400V 50Hz 1600KVA Standby / 1500KVA Prime   |
| Major Components     | Generator (1600 frame SR5)<br>Radiator (44CTD)<br>Controls: EMCP4.2, ADEM 3<br>CDVR                 |
| Features             | Batteries, Alternator (24V), Primary Fuel Filter, Manual Pre-lube Pump, Customer Bus Bar Connection |

