



### **MAIN FEATURES**

Highest quality and reliability.	Wide range of standard and optional equipment.
ComAp InteliLite AMF 25 controller.	Engine heater – ready to load just after start.
Ready to control MAINS – GENERATOR transfer switch.	Drip tray,
Configured for both manual and automatic mode (MRS + AMF).	Anticorrosion coating: frame - Zr, canopy - Zr, Al-Zn.
Wide range of remote communications options.	Brushless alternator.
Schneider NSX type GCB.	



The presented image is for illustration purpose only.

### **GENERAL DATA**

9	
Code	DPX-17951
Standby power E.S.P. [kVA] / [kW]	451,0 / 361,0
Prime power P.R.P. [kVA] / [kW]	410,0 / 328,0
Prime current P.R.P [A]	592,0
Frequency [Hz]	50
Voltage [V]	400
Exhaust emission	fuel optimized
Fuel type	Diesel (EN 590)
Fuel consumption - 50% load [l/h]	41,1
- 75% load [l/h]	59,9
- 100% load [l/h]	78,8
- 110% load [l/h]	87,8
Standard fuel tank capacity [1]	990
Autonomy with 100% load [h]	12,6
Engine control voltage [V]	24
Weight without fuel [kg]	4400
Dimensions L x W x H [mm]	4560 x 1961 x 2521
Guaranteed noise power Lwa [dBA]	98
Acoustic pressure Lpa (7m) [dBA]	$69,1 \pm 1,9$

## Nominal power P.R.P:

Prime power available in variable load application in accordance with ISO 8528, 10% overload capacity is available for a period of 1 hour within a 12-hour period of operation. Average power consumption should not exceed 70% PRP for each 24-hour period of operation.

## Stand-by power E.S.P.:

Emergency standby power rating is applicable for supplying emergency power for the duration of a utility power interruption. No overload allowed, limited to 200h of operation per year. Max mean load factor of 70% of rated power over 24-hour period of operation.

#### Remark

Ratings represent the genset performance capabilities to standard conditions specified in ISO 8528-1

### Norms and directives:

- Machinery directive 2006/42/EC
- Low voltage directive 2014/35/EC
- EC directive 2014/30/EC
- Noise directive 2000/14/EC
- Emission directive 97/68/ECISO 8528-1:2018, ISO 8528-5:2018
- ISO 8528-13:2016
- EN 60204-1





#### STANDARD CONTROLLER

Controller type: ComAp InteliLite AMF 25

Easy to operate, intuitive graphical interface

Real time clock with battery supply

Stan-by and Prime power applications, AMF function available

Flexible event based history with up to 350 events

3 Phase generator current measurement

Generator and Mains phase voltage measurement

Active/reactive power measurement

Active and reactive energy counter

Running hours counter, multipurpose flexible timers

Battery charging alternator circuit connection

Comprehensive gen-set protections

Wide range of communication capabilities including:

- CAN and USB on board
- Internet access using Ethernet, GPRS or 4G module
- Support for Modbus and SNMP protocols

Cloud-based monitoring and control via WebSupervisor

Active SMS or e-mails (module required)

Geofencing and tracking via WebSupervisor

Operating temperature  $-20 + 70^{\circ}$ C

IP65 operator interface protection



#### **ENGINE**

## **ALTERNATOR**

Brand	Scania	Nominal Voltage [V]	400
Type	DC13 072A 02-12	Nominal power factor (cos phi)	0,8
Made in	Sweden	Ambient temperature, altitude	40 °C, 1000m a.m.s.l
Engine power [kW]	355,0	Nominal Power [kVA]	410,0
Emission standard*	fuel optimized	IP protection	IP 23
Rotation per minute [rpm]	1500	No of bearing	single bearing
Engine governor	electronic	Coupling	direct
Governor class**	G3	Technology	brushless
Displacement [l]	12,7	Short circuit maintaining capacity	270% 10s
No of cylinder	6	Efficiency [%]	93,3
Fuel system	unit injectors, PDE	Insulation class	Н
Electrical system [V]	24	Total harmonic content THD [%]	1,5
Cooling system capacity [l]	38,0	Reactance Xd'' [%]	15,1
Oil pan capacity [l]	36,0	Voltage regulator type	DVR, digital
Fuel type	Diesel (EN 590)	Voltage measurement	3 phases
		Voltage accuracy [%]	+/- 0,25
		AVR supply system	auxiliary winding
		AVR supply optional	PMG
		Made in	EU

<sup>\*</sup> According directive 97/68/EC non road mobile machinery engine emission.

<sup>\*\*</sup> According ISO 8528-5:2018



# **STANDARD EQUIPMENT**

# **OPTIONAL EQUIPMENT**

Scania DC13 072A 02-12 engine	✓	Battery disconnection switch	
Electronic engine speed governor	✓	GCB 4P Schneider NSX Micrologic 2.3	
Oil low pressure switch	✓	Power Lock type power output	
Oil pressure sensor	✓	Power socket box	
Engine high temperature switch	✓	Transfer switch controlled by generator controller	
Engine high temperature sensor	✓	Transfer switch with ATS controller	
Engine preheating with thermostat	✓	GPRS communication card	
Engine oil Titan Cargo 15W40	✓	Ethernet card	
Fuel filter with water separator	✓	RS 485, RS 232 card	
Coolant Fuchs Maintain Fricofin LL-35	✓	Remote display	
Coolant inlet outside of the canopy	✓	Drip space level sensor	
Starting batteries 2x180Ah	✓	External fuel tank 1 000 – 10 000 l	
Battery charger	✓	3-way valve for external fuel tank connection	
GCB Schneider NSX 630 3P + Mic.2.3	✓	Fuel tank filling pump and shut-off valve	
GCB shunt release coil	✓	Non-standard canopy color (RAL palette)	
Controller ComAp InteliLite AMF 25	✓	Oil draining hand pump	
Acoustic alarm	✓		
Emergency stop button	✓		
Silenced canopy made with AlZn.	✓		
Standard color RAL 7024	✓		
Fuel tank installed in drip tray	✓		
Welded frame with fuel tank	✓		
Fuel inlet inside, protected by canopy locked doors	✓		
Fuel level measurement	✓		
Exhaust compensator and silencer	✓		
Engine and alternator vibro isolators	✓		
Transportation brackets	✓		



## **INSTALLATION GUIDELINES**

Power terminal	GCB terminal
Recommended cable for up to 30m power cable way	Flexible 2x5x150 mm <sup>2</sup>
Recommended cable for do 30m generator heater supply	Flexible 3x2,5 mm <sup>2</sup>
*For additional cable connection with FOGO ATS see ATS wiring diagram	
Exhaust pipe min diameter (max. 7 m, 4 bends)	133 mm
Exhaust pipe min diameter (max. 15 m, 4 bends)	

# **MAINTENANCE GUIDELINES**

Fuel filters replacement	500 h / 1 year
Oil replacement	After first 100h, then every 500 h / 1 year
Oil filters replacement	After first 100h, then every 500 h / 1 year
Coolant replacement	1000 h / 2 years
Battery replacement	2 years
Electrical installation supervising	According to local requirements, at least once per year

## **WARRANTY**

Continuous work generators	12 months up to 1000 working hours
----------------------------	------------------------------------